

SECTION 23 09 93
SEQUENCE OF OPERATIONS FOR HVAC CONTROLS

PART 1 GENERAL

1.1 SUMMARY

- A. Section includes sequence of operation for:
 - 1. Fan coil units.

1.2 SUBMITTALS

- A. Section 01 33 00 - Submittal Procedures: Submittal procedures.
- B. Shop Drawings: Indicate mechanical system controlled and control system components.
 - 1. Label with settings, adjustable range of control and limits. Submit written description of control sequence.
 - 2. Submit flow diagrams for each control system, graphically depicting control logic.

1.3 CLOSEOUT SUBMITTALS

- A. Section 01 70 00 - Execution and Closeout Requirements: Closeout procedures.
- B. Project Record Documents: Record actual locations of components and set points of controls, including changes to sequences made after submission of shop drawings.

PART 2 PRODUCTS

Not Used.

PART 3 EXECUTION

3.1 FAN COIL UNITS

- A. Single temperature, remote wall-mounted thermostat set at 75 degrees F. Thermostat maintains constant space temperature during day and 15 degrees F cooler at night.

END OF SECTION 23 09 93